

+



**2011 WASTEWATER POLLUTION CONTROL
PLANT ANNUAL REPORT**

Certificate of Approval No 3560-8A8LEY
Sewage Works No. 110000953

TABLE OF CONTENTS

1.0	INTRODUCTION
	➤ Classification and Control Document Information.
2.0	CONTACT INFORMATION
	➤ Owner/Operator contact information
3.0	WASTEWATER TREATMENT PLANT & TREATMENT PROCESS
4.0	COMPLIANCE WITH TERMS AND CONDITIONS OF CERTIFICATE OF APPROVAL
4.1	PERFORMANCE
4.1.1	Wastewater flows to the WPCP
4.1.2	Waste Stabilization Pond Effluent Quality
4.1.3.	Waste Stabilization Pond Loading
4.1.3	Wetland Effluent Quality
4.2	MONITORING AND RECORDING
	➤ Table I- Monthly Sewage In-flow to Treatment Plant
	➤ Table II-- Annual Flows to the WPCP
	➤ Table III- C of A Waste Stabilization Pond Effluent Parameters
	➤ Table VIII – Compliance to sampling frequency
	➤ Table V– Waste Stabilization Pond – weekly lab results
	➤ Table VI–Wetland Final Effluent – weekly lab results
	➤ Table VII- Lagoon Loading- from weekly lab results
	➤ Table IX- Brighton WPCP Performance
4.3	OPERATIONS AND MAINTENANCE
	➤ Summary of Operations
	➤ Summary of Maintenance
	➤ Summary of Environmental or Operating Problems
4.4	REPORTING
4.5	FUTURE ACTION PLAN
5.0	CONCLUSION

1.0 INTRODUCTION

The Municipality of Brighton is pleased to present its Annual Performance Report for wastewater treatment for the operating period of January 1 to December 31, 2011.

- Brighton's Water Pollution Control Plant services a population of approximately 6,297 consisting of 2,800 residential and commercial accounts including Presqu'ile Park. The Ontario Water Wastewater Certification Office classifies the Water Pollution Control Plant as Wastewater Treatment Class 1 facility and Wastewater Collection Class 2 collection system.

The Brighton Wastewater Pollution Control Plant operates under a Amended Certificate of Approval Number #3560-8A8LEY (while work is being completed in the next 5 years) issued by the Ministry of Environment.

CONTROL DOCUMENT INFORMATION

1 Type of Control Document	Number	Issue Date	Effluent Monitoring Requirements (Yes/No)	Effluent Reporting Requirements (Yes/No)
C of A Sewage Works	#3560-8A8LEY	17/11/10	YES	YES
C of A Sludge Drying Beds	3-0381-96-006	8/01/96	N/A	N/A
C of A Composting Site	A710120	2/05/97	N/A	N/A

There were no biosolids pumped to the drying beds during this reporting period and no material was utilized or removed from the composting site.

2.0 CONTACT INFORMATION

For information or questions regarding this report please contact:

The Corporation of the Municipality of Brighton
35 Alice Street, P.O. Box 189
Brighton, ON K0K 1H0
Telephone: (613) 475-0670
Fax: (613) 475-3453

Andrew Drezwiecki, P.Eng., Director
Public Works & Development
67 Sharp Road, Brighton, ON K0K 1H0
adrezwoecki@brighton.ca
Telephone: (613) 475-1162
Fax: (613) 475-2599

Brighton WPCP Operators: Keith Lee, WWTI/WWC II Operator-in-Charge
Public Works & Environmental Services
klee@brighton.ca
Telephone: (613) 475-1162
Cell: (613) 849-8920

Scott Hodgson, Class I WWC/WWT
Public Works & Environmental Services
shodgson@brighton.ca
Telephone: (613) 475-1162

Consultant: Mike Gundry
AECOM
Water Group
300 Water Street
Whitby, On., L1N 9J2

2.1.1.1.1.1.1.1.1
Laboratories

Accredited Laboratory: Caduceon Environmental
285 Dalton Ave., Kingston, ON K7M 6Z1
Phone: (613) 544-2001
Fax: (613) 544-2770

3.0 WASTEWATER TREATMENT PLANT DESCRIPTION & TREATMENT PROCESS

The sewage works in Brighton consists of:

- a 0.7 hectare aerated lagoon (Lagoon #1) with two mechanical surface aerators. The effluent from the aeration lagoon passes through a chemical mixing chamber where alum is added before entering the waste stabilization pond;
- a 5.44 hectare waste stabilization pond (Lagoon #2) is a facultative lagoon where wastewater stabilization is carried out by a combination of aerobic, anaerobic and facultative bacteria.
- a constructed wetland having a surface area of 6.2 hectare, located south of the existing waste stabilization pond consisting of Wetland Cell #1 (north cell) and Wetland Cell #2 (south cell) with alternating deep zones and vegetative terraces. The effluent from the constructed wetlands is continuous and discharges to a natural wetland that borders Presqu'île Bay located off the northeast shore of Lake Ontario;
- a 2-cell drying bed to service the existing sewage treatment lagoons; sludge that accumulates in the lagoons may be periodically pumped to drying beds.

The hydraulic capacity of the sewage works has been re-rated at 4,600 m³/day since the constructed wetlands were incorporated to the treatment system in the summer of 2000. Approximately 40% of the sanitary sewage from the Brighton collection system flows by gravity to the aerated lagoon; the remainder of the flow (60%) was collected at the Harbour Street Sewage Pumping Station where it is pumped through a forcemain to the WPCP. The pumping station is equipped with three dry well centrifugal pumps that pump wastewater through a forcemain to the aerated lagoon. A standby diesel generator is on-site at the pumping station to provide electricity to the pumps during power outage events.

Brighton's wastewater treatment system is a low-tech approach based on purifying the wastewater through biological activity in a lagoon-based system. Raw wastewater enters the aerated lagoon (Lagoon #1) where it is mixed and oxygenated. The added oxygen from aeration allows aerobic microorganisms to reduce organic matter and nutrients, and reduces odour potential in the wastewater. The effluent from the aerated lagoon then passes through a mixing chamber where Alum (Aluminum Sulfate) is added. Alum is a flocculent used in wastewater ponds to precipitate soluble phosphorus and aids in the settling of many other substances. The effluent then flows to the waste stabilization pond (Lagoon #2) where the bound solids settle to the bottom and the organic portions are decomposed through microbial action. Dissolved materials such as nitrogen and phosphorous are used by green algae in the pond for cell growth. The effluent from the waste stabilization pond then enters the constructed wetland for final polishing where the water is further filtered and cleansed. The natural processes occurring in the lagoons and wetland system produce a good quality effluent that is monitored regularly by licensed operators. Treatment performance from lagoon-based systems is susceptible to low temperature conditions and associated negative effects on biological treatment performance. Ammonia removal rates and microbial growth typically decrease with lower temperatures. The Certificate of Approval provides changes in concentration limits for Ammonia in the waste stabilization pond and constructed wetlands from October to April to provide allowances for cold temperatures that result in lower nitrification rates.

Analyses are taken in both the influent (raw sewage) and the effluent at the lagoon and wetlands to determine the amount of treatment achieved. The results must comply with MOE guidelines and Certificate of Approval effluent concentration limits and objectives.

4.0 COMPLIANCE WITH TERMS AND CONDITIONS OF CERTIFICATE OF APPROVAL

4.1 Performance

4.1.1 *Wastewater Flow to the WPCP*

Certificate of Approval 2.(a) The Owner shall ensure that the flow of sewage into the sewage treatment works does not exceed the average daily flow of 4,600 m³/day for a period of any twelve (12) consecutive calendar months.

The average daily flow for 2011 was 3,696 m³/day, which represents 80% of the average day design capacity of 4,600 m³/day. The maximum annual daily flow for 2011 occurred on March 12, 2011 where heavy precipitation contributed to a peak flow of 11,899 m³/day. Peak monthly flow of 198,704 m³ occurred in March due to heavy precipitation that month. Annual flow of sewage to the WPCP was 1,351,551 m³ in 2011 with *approximately* 60% of the wastewater entered via the pumping station and 40% flowing by gravity from the remainder of the sanitary collection system.

Table I – Monthly Sewage In-flow to Treatment Plant

Date	Total Flow m ³	Avg. Flow m ³ /day	Max. Day Flow m ³	% Avg Day/Design Cap
January	87,273	2,815	3,935	61%
February	85,999	3,071	8,073	67%
March	198,704	6,410	11,899	139%
April	155,182	5,173	7,684	112%
May	148,894	4,803	5,740	104%
June	109,064	3,635	4,552	79%
July	84,233	2,717	3,517	59%
August	106,377	3,432	6,571	75%
September	73,625	2,454	2,106	53%
October	83,578	2,696	3,087	59%
November	82,646	2,755	5,824	60%
December	135,976	4,386	6,551	95%
Annual	1,351,551	3,696	11,899	80%

Volume of influent of wastewater to lagoon #2 measured 1,351,551m³ See Table II.

Average per capita daily wastewater flow to Brighton WWTP was approximately 0.58 m³/capita in 2011, which includes domestic, industrial and commercial contributions as well as infiltration and inflow. (Based on a population of 6,297 and an average daily flow of 3,696 m³/day.) The population number includes an estimated 182 persons to account for the seasonal population of Presqu'île Provincial Park.

The total flow of wastewater to the treatment plant in 2010 was 1,123,106m³; flows in 2011 were approximately 20% higher

Table II- Annual Flows to the WPCP

Date	2011	2010	2009	2008	2007
January	87,273	110,373	99,491	112,038	140,264
February	85,999	77,081	111,628	103,034	78,345
March	198,704	120,468	147,025	149,246	120,276
April	155,182	92,975	160,693	186,347	148,787
May	148,894	85,164	132,309	125,367	113,879
June	109,064	94,826	93,962	91,382	84,874
July	84,233	94,649	91,162	88,538	78,451
August	106,377	81,353	83,029	89,577	72,287
September	73,625	70,871	76,566	76,298	67,372
October	83,578	75,782	103,296	77,068	70,893
November	82,646	85,682	102,340	84,512	73,350
December	135,976	133,882	134,422	136,290	86,621
Annual	1,351,551	1,123,106	1,335,923	1,319,697	1,135,399

4.1.2 Waste Stabilization Pond Effluent Quality

Certificate of Approval 2.(b) The owner shall design, construct and/or operate the sewage treatment works such that the concentrations of the materials named below as effluent parameters are not exceeded in the effluent from the waste stabilization pond (Lagoon #2):

Table III – C of A Waste Stabilization Pond Effluent Parameters

Effluent Parameters	Concentration in Effluent	Loading in Effluent
CBOD ₅	30.0 mg/L	138.0 kg./day
Suspended Solids	40.0 mg/L	184.0 kg./day
Ammonia & Ammonium Nitrogen (May 1 to Oct. 30) ¹	14.0 mg/L ¹	64.4 kg./day ¹
(Nov. 1 to Apr. 30) ²	17.0 mg/L ²	78.2 kg./day ²
Total Phosphorus	1.0 mg/L	4.6 kg./day

Waste Stabilization Pond Effluent Summary:

- The Biological Oxygen Demand is the amount of oxygen used by micro-organisms as they decompose organic matter in the effluent sample for five days. High BOD in effluent means a large quantity of oxygen was needed to break down the organic matter and identifies a large amount of organic matter in the effluent indicating inadequate treatment. The CBOD₅ average concentration from the waste stabilization pond effluent in 2011 was 7.54 mg/L; the C of A limit is 30.0 mg/L CBOD₅ based on the average concentration of all samples taken.
- Total Suspended Solids in effluent are composed of settleable solids and nonsettleable solids depending on the size, shape and weight of the solid particles; large sized particles tend to settle more rapidly and are largely removed in the waste stabilization pond. Suspended Solids concentration limit from the waste stabilization pond effluent is 40.0 mg/L. The annual average of Total Suspended Solids was 17.85mg/l from the waste stabilization pond.
- Total Phosphorus (TP) refers to the amount of phosphorus in a sample. Excess TP stimulates algae and weed growth that may cause fluctuations in dissolved oxygen in the receiving waters. Total Phosphorus limits for the waste stabilization pond is based on the monthly average concentration of the parameter; the C of A limit is 1.0 mg/L TP. Monthly average concentration of Total Phosphorus in 2011 ranged from 0.16 – 1.20 mg/L.
- The C of A limits for Ammonia is 14.0 mg/L from May to October and 17.0 mg/L from November to April. Non-compliance with respect to concentrations of (Ammonia + Ammonium) Nitrogen in the effluent is deemed to have occurred when the *‘monthly average’* concentration of the parameter listed in Table III is exceeded in any calendar month. Ammonia concentrations from May to October averaged 16.71 mg/L; and averaged 12.96 mg/L in November to April.

A summary of the Lagoon Loading is provided in Table VII.

A summary of the overall performance of the wastewater system is provided in Table IX. It is noted that there were exceedances of Ammonia and Total Phosphorus in 2011.

4.1.3 Wetland Effluent Quality

Certificate of Approval 5.(a) the Owner shall use best effort to operate the sewage treatment works with the objective that the concentrations of the materials named below as effluent parameters are not exceeded in the effluent from constructed wetland:

Table IV – C of A Constructed Wetland Effluent Objectives

Constructed Wetland Effluent Parameter	Concentration
CBOD ₅	15.0 mg/L
Suspended Solids	15.0 mg/L
Ammonia + Ammonium Nitrogen (May 1 to October 30) ¹	10.0 mg/L ¹
(November 1 to April 30) ²	15.0 mg/L ²
Total Phosphorus	0.80 mg/L

Table V lists the weekly lab results of the Waste Stabilization Pond.

Wetland Effluent Summary:

- The average concentration of CBOD₅ from the constructed wetland effluent in 2011 was 5.10 mg/L; the C of A objective is 15.0 mg/L CBOD₅ based on the average concentration of all samples taken.
- Suspended Solids concentration limit from the constructed wetland effluent is 15.0 mg/L. The annual average concentration of Total Suspended Solids was 7.65 mg/L from the constructed wetland based on the average concentration of all samples taken.
- Total Phosphorus limits for the constructed wetland is based on the monthly average concentration of the parameter; the C of A limit is 0.80 mg/L. Monthly average concentrations of Total Phosphorus in 2011 ranged from 0.15 – 0.68 mg/L.
- Limits for Ammonia from the constructed wetland are 10.0 mg/L from May to October and 15.0 mg/L from November to April. Non-compliance with respect to concentrations of (Ammonia + Ammonium) Nitrogen in the effluent is deemed to have occurred when the *‘monthly average’* concentration of the parameter listed in Table IV is exceeded in any calendar month. Ammonia concentrations from May to October averaged 13.21 mg/L; and averaged 13.60 mg/L from November to April.
- There were exceedances as defined in the Certificate of Approval of any of the parameters with respect to concentration from the constructed wetland effluent.
- Lack of sunlight, plant production, decreased temperatures and ice cover in winter months directly affects treatment capability of a natural treatment process by limiting dissolved oxygen concentrations which may contribute to elevated food to microorganism ratio (F:M) conditions. Algae, coon tail weed and plants consume nitrogen and phosphorus in the wastewater; lack of this activity in winter months limits the reduction of Ammonia and Phosphorus in the final effluent.

Certificate of Approval (5.)(b) states that the geometric mean density of *E. Coli* should not exceed 200 organisms per 100 ml. for any calendar month. *E. coli* are sampled once a month from the waste stabilization pond basis as per C of A. See results. *E. Coli* levels were above 200 organisms per 100 ml on five occasions in the lagoon and five occasions in the wetland.

Table VI lists the weekly lab results of the Constructed Wetland Effluent including monthly E. Coli

4.2 **Monitoring and Recording**

Certificate of Approval 4.(a) Annual calibration of flow measuring devices was performed on August 10, 2011 by Measuremax.

Certificate of Approval 4.(b)(c)(d) – Table VIII demonstrates compliance with frequency of sampling of raw sewage, waste stabilization pond effluent and wetland effluent.

4.3 **Operations and Maintenance**

Operations:

Operation now includes an inspection and flushing program at the Presqu'ile Park lift station. Regular inspection and flushing aids in preventing blockages, flooding, and any anaerobic activity that may occur in the forcemain. This ensures a far more consistent and stable influent from the park.

A new alarm system was updated at the Harbour St. lift station. This system continuously monitors various equipment and processes, and can provide notification to operators when something is not functioning correctly. Weekly Tests are performed by operators to ensure reliability of equipment.

Additionally, wastewater operators will continue to attend courses and workshops in order to further their education and remain current on all industry regulations and best practices.

Upgrades have also been carried out at the lagoon with the installation of a new Alarm system. This new system will notify the Operator on call if there are any problems.

Maintenance:

A regular maintenance schedule is in place in order to service many components of our system. Scheduled maintenance is key in keeping equipment and infrastructure properly serviced while minimizing breakdowns.

Where feasible, building and facility maintenance is conducted by wastewater operators. This allows operators to stay "hands on" with all aspects of the system, and helps reduce operating costs.

Due to the aging infrastructure flushing and camera work is being carried out to ensure reliability of the system on a yearly basis.

Environmental/Operating Problems:

There were no environmental or operating problems in the 2010 reporting period.

Table V

WASTE POND EFFLUENT-2011										
	CBOD ₅	TSS	T.P.	Ammonia	TKN	Nitrite (N)	Nitrate (N)	E. Coli	Temperture/pH	
C of A	30 mg/L	40 mg/L	1.0 mg/L	(May-Oct)14	mg/L	mg/L	mg/L	200/100ml/mo	Average	
CBOD results <2 recorded as 1.0			Monthly Avg.	(Nov-Apr) 17		results <0.1 recorded as .1			for	
				monthly aver.					Month	
04-Jan	8.00	18.00	0.72	14.30	14.70	0.10	0.10	1540		7.6
11-Jan	7.00	32.00	1.21	15.80	20.00	0.10	0.10			
18-Jan	10.00	22.00	1.23	17.30	20.80	0.10	0.10			
25-Jan	19.00	22.00	1.01	19.40	19.40	0.10	0.10			
Average	11.00	23.50	1.04	16.70	18.7	0.10	0.10	1540		3.9
01-Feb	17.00	44.00	1.36	20.20	22.00	0.10	0.10	<4000		
08-Feb	13.00	32.00	1.27	22.40	21.00	0.10	0.20			
15-Feb	8.00	28.00	1.21	19.20	19.70	1.00	0.10			
22-Feb	5.00	24.00	0.97	19.00	21.10	0.60	0.60			7.6
Average	10.75	32.00	1.20	20.20	20.95		0.25			2.0
01-Mar	8.00	24.00	0.73	16.1	19.70	0.40	0.60	3600		
08-Mar	11.00	28.00	0.74	7.20	10.20	0.40	1.20			
15-Mar	12.00	18.00	0.36	3.40	6.70	0.20	1.80			
22-Mar	22.00	30.00	0.41	8.30	8.80	0.50	1.30			
29-Mar	9.00	28.00	0.47	8.30	11.80	0.50	1.10			7.7
Average	12.40	25.60	0.54	8.66	11.44		1.20			4.5
05-Apr	9.00	28.00	0.37	5.30	11.10	0.50	0.90	340		
12-Apr	19.00	26.00	0.57	4.90	12.40	0.50	0.80			
19-Apr	10.00	20.00	0.64	11.00	13.90	0.10	0.50			
26-Apr	2.00	6.00	0.22	9.50	9.70	0.10	0.30			
Average	10.00	20.00	0.45	7.68	11.78		0.63			7.8
03-May	7.00	8.00	0.28	8.60	8.10	0.60	0.60	20		9.6
10-May	14.00	22.00	0.58	9.90	11.80	0.60	0.40			
17-May	12.00	36.00	0.54	9.00	11.40	0.50	0.20			
24-May	10.00	4.00	0.59	8.60	12.60	0.10	0.20			
31-May	2.00	8.00	0.25	14.00	14.10	0.10	0.20			7.9
Average	9.00	15.60	0.45	10.02	11.60		0.32			16.6
07-Jun	4.00	6.00	0.35	15.00	17.00	0.10	0.10	20		
14-Jun	2.00	8.00	0.45	18.00	20.20	0.10	0.10			
21-Jun	2.00	2.00	0.01	15.10	14.80	0.10	0.50			
28-Jun	2.00	4.00	0.30	12.90	12.20	0.50	0.90			
Average	2.50	5.00	0.28	15.25	16.05		0.40			22.9
05-Jul	5.00	16.00	0.59	17.60	17.50	0.40	0.10	20		
12-Jul	12.00	14.00	0.64	18.50	18.50	0.10	0.10			
19-Jul	7.00	12.00	0.62	18.10	17.20	0.10	0.10			
26-Jul	11.00	25.00	0.37	16.40	21.00	0.10	0.10			
Average	8.75	16.75	0.56	17.67	18.55		0.10			8.0
02-Aug	2.00	16.00	0.46	17.70	20.90	0.10	0.10	20		0.0
09-Aug	2.00	8.00	0.41	17.60	20.00	0.10	0.10			
16-Aug	2.00	6.00	0.43	17.80	17.90	0.10	0.10			
23-Aug	2.00	4.00	0.49	18.70	20.20	0.10	0.10			
30-Aug	2.00	8.00	0.41	20.40	20.50	0.10	0.10			8.2
Average	2.00	8.40	0.44	18.44	19.90		0.10			23.72
06-Sep	5.00	3.00	0.36	19.50	19.50	0.10	0.10	20		
13-Sep	2.00	2.00	0.37	21.20	20.60	0.10	0.10			
20-Sep	2.00	4.00	0.37	23.00	23.50	0.10	0.10			
27-Sep	2.00	2.00	0.42	21.40	24.50	0.10	0.10			
Average	2.75	2.75	0.38	21.28	22.03		0.10			8.0
04-Oct	2.00	7.00	0.47	22.40	23.50	0.6	0.1	20		20.5
11-Oct	2.00	9	0.43	22.70	26.60	0.50	0.10			
18-Oct	2.00	2.00	0.40	23.00	27.00	0.50	0.10			
25-Oct	2.00	4.00	0.46	22.10	22.80	0.10	0.10			
Average	2.00	5.50	0.44	22.55	24.98		0.10			8.0
01-Nov	3.00	5.00	0.27	19.80	21.50	0.10	0.10	20		13.9
08-Nov	2.00	4.00	0.28	19.30	20.8	0.10	0.10			
15-Nov	2	5.00	0.23	20.90	21.80	0.10	0.20			
22-Nov	2.00	5.00	0.19	19.40	19.20	0.40	0.20			
29-Nov	2.00	4.00	0.24	16.50	22.80	0.40	0.30			8.0
Average	2.20	4.60	0.24	19.18	21.22		0.18			8.6
06-Dec	2.00	10.00	0.31	15.00	16.00	0.60	0.90	1820		
13-Dec	3.0	7.0	0.2	12.0	12.3	0.5	1.0			
20-Dec	4.00	5.00	0.12	9.80	11.70	0.50	0.90			
27-Dec	6.00	16.00	0.46	9.30	14.70	0.40	0.80			
Average	3.75	9.50	0.28	11.53	13.68		0.90			7.9
Average	6.47	14.14	0.5	15.72	17.54	0.28	0.36			5.1
Cof A Par.	30 mg/l	40 mg/l	1.0 mg/l	(May-Oct)14mg/l						
				(Nov-Apr)17mg/l						

Table VI

WETLAND FINAL EFFLUENT										
DATE	CBOD ₅	TSS	TP Month	NH ₃ Month		TKN	Nitrite (N)	Nitrate (N)	E. Coli	
ng/L recorded as 1.0	Average	Average	Average	Average						
04-Jan	4.00	6.00	0.37	13.50		13.20	0.10	0.10	240	
11-Jan	6.00	8.00	0.80	14.80		18.80	0.10	0.10		
18-Jan	5.00	12.00	0.85	17.20		20.10	0.10	0.10		
25-Jan	11.00	12.00	0.69	16.7		17.00	0.10	0.10		
				15.55						
Average	6.50	9.50	0.68	15.55		17.28	0.10	0.10		
01-Feb	9.00	18.00	0.68	19.30		20.40	0.10	0.10	<4000	
08-Feb	11.00	20.00	0.88	22.80		19.90	0.10	0.10		
15-Feb	5.00	14.00	0.60	17.30		18.00	6.10	0.20		
22-Feb	7.00	18.00	0.56	21.5		24.20	0.10	0.10		
Average	8.00	17.50	0.68	20.23		20.63	1.60	0.13		
01-Mar	8.00	8.00	0.54	19.60		21.10	0.10	0.20	460	
08-Mar	66.00	20.00	0.54	11.10		12.20	0.60	0.90		
15-Mar	5.00	6.00	0.25	5.40		6.60	0.40	1.40		
22-Mar	11.00	14.00	0.17	5.30		6.30	0.50	0.80		
29-Mar	3.00	12.00	0.14	7.60		8.50	0.20	0.90		
Average	18.60	12.00	0.33	9.80		10.94	0.36	0.84		
05-Apr	4.00	12.00	0.09	3.50		8.40	0.10	0.70	20	
12-Apr	6.00	14.00	0.11	2.20		7.90	0.40	0.80		
19-Apr	3.00	6.00	0.21	7.00		8.20	0.10	0.90		
26-Apr	6.00	16.00	0.52	9.2		11.00	0.50	0.70		
Average	4.75	12.00	0.23	5.48		8.88	0.28	0.78		
03-May	2.00	4.00	0.18	8.60		7.50	0.10	0.30	20	
10-May	5	3	0.07	3.3		3.40	0.70	1.10		
17-May	2.00	4.00	0.13	3.62		3.70	0.60	0.40		
24-May	3.00	4.00	0.27	7.90		8.40	0.10	0.10		
31-May	2.00	6.00	0.27	10.6		10.40	0.10	0.10		
Average	2.80	4.20	0.18	6.80		6.68				
07-Jun	2.00	6.00	0.41	10.20		11.90	0.10	0.20	80	
14-Jun	3.00	6.00	0.39	15.70		17.60	0.10	0.10		
21-Jun	2.00	2.00	0.15	9.90		9.50	0.10	0.10		
28-Jun	2.00	3.00	0.36	17.1		16.60	0.60	0.30		
Average	2.25	4.25	0.33	13.23		13.90				
05-Jul	4.00	8.00	0.50	17.60		16.30	0.10	0.10		
12-Jul	2.00	18.00	0.08	4.90		4.80	1.40	0.50		
19-Jul	2.00	3.00	0.09	3.70		3.70	0.10	0.10		
26-Jul	7.00	8.00	0.34	11.1		13.10	0.10	0.20		
Average	3.75	9.25	0.25	9.33		9.48				
02-Aug	2.00	6.00	0.25	11.80		15.30	0.10	0.10	60	
09-Aug	12.00	4.00	0.34	13.20		15.90	0.10	0.10		
16-Aug	2.00	5.00	0.10	15.70		15.80	0.10	0.10		
23-Aug	2.00	2.00	0.30	15.60		17.10	0.10	0.10		
30-Aug	2.00	2.00	0.27	17.4		17.40	0.10	0.10		
Average	4.00	3.80	0.25	14.74		16.30				
06-Sep	2.00	3.00	0.11	13.90		13.50	0.10	0.10	880	
13-Sep	2.00	4.00	0.27	16.70		16.70	0.10	0.10		
20-Sep	2.00	3.00	0.18	17.70		19.40	0.10	0.10		
27-Sep	2.00	2.00	0.36	20		21.00	0.10	0.10		
Average	2.00	3.00	0.23	17.08		17.65				
04-Oct	2.00	4.00	0.29	20.5		20.00	0.10	0.10	740	
11-Oct	2.00	8.00	0.28	18.60		21.90	0.10	0.20		
18-Oct	4.00	6.00	0.21	22.40		25.00	0.10	0.10		
25-Oct	2.00	8.00	0.32	20.2		21.60	0.10	0.20		
Average	2.50	6.50	0.28	20.43		22.13				
01-Nov	2.00	2.00	0.12	19.60		21.50	0.10	0.20	20	
08-Nov	6.00	10.00	0.24	19.90		19.40	0.10	0.20		
15-Nov	3.00	5.00	0.16	17.50		18.20	0.30	0.40		
22-Nov	2.00	2.00	0.16	14.6		19.40	0.40	1.20		
Average	3.25	4.75	0.17	17.90		19.63				
06-Dec	2.00	2.00	0.18	12.50		15.00	0.50	1.30	20	
13-Dec	2.00	4.00	0.10	12.00		11.40	0.40	1.70		
20-Dec	4.00	6.00	0.09	9.10		10.00	0.40	1.70		
27-Dec	3.00	8.00	0.22	7.65		11.20	0.10	1.50		
00-Jan										
Average	2.75	5.00	0.15	10.31		11.90				
		7.64	0.31							
CofA obj.	15.00	15.00	0.8	(May-Oct)14mg/l (Nov-Apr)17mg/l					200/100ml/mo	200/100ml/mo

**Table VII
Lagoon Loading**

Total Flow (m ³)	Average Flow m ³ /day	Average CBOD mg/L	Loading BOD kg/day	Average S.S. mg/L	Loading S.S. kg/day	Average NH ₃ mg/L	Loading NH ₃ kg/day	Average TKN mg/L	Loading TKN kg/day	Average T.Phos mg/L	Loading T.Phos kg/day
87,273	2,815	11.00	30.97	23.50	66.16	16.70	47.01	18.73	52.72	1.04	2.93
85,999	3,071	10.75	33.02	32.00	98.28	20.20	62.04	20.95	64.35	1.20	3.69
198,704	6,410	12.40	79.48	25.60	164.09	8.66	55.51	11.44	73.33	0.54	3.47
155,182	5,173	10.00	51.73	20.00	103.45	7.68	39.70	11.78	60.91	0.45	2.33
148,894	4,803	9.00	43.23	15.60	74.93	10.02	48.13	11.60	55.72	0.45	2.15
109,064	3,635	2.50	9.09	5.00	18.18	15.25	55.44	16.05	58.35	0.28	1.01
84,233	2,717	8.75	23.78	16.75	45.51	17.67	48.00	18.55	50.40	0.56	1.51
106,377	3,432	2.00	6.86	8.40	28.82	18.44	63.28	19.90	68.29	0.44	1.51
73,625	2,454	2.75	6.75	2.75	6.75	21.28	52.21	22.03	54.05	0.38	0.93
83,578	2,696	2.00	5.39	5.50	14.83	22.55	60.80	24.98	67.33	0.44	1.19
82,646	2,755	2.20	6.06	4.60	12.67	19.18	52.84	21.22	58.46	0.24	0.67
135,976	4,386	3.75	16.45	9.50	41.67	11.53	50.55	13.68	59.98	0.28	1.22
1,351,551											
112,629	3,696	6.43	26.07	14.10	56.28	17.53	54.64	17.57	60.32	0.52	1.88
73,625						13.99	51.28				
198,704											
	4,600	30.00	138.00	40.00	184.00	May-Oct. 14.0 ¹	May-Oct. 64.4 ¹			1.00	4.60
						Nov.-Apr. 17.0 ²	Nov.-Apr. 78.2 ²				

Table VIII

Certificate of Analysis 4.(b) Samples of raw sewage shall be collected at locations acceptable to the District Manager and analyzed for at least parameters 1 to 4 at the indicated minimum frequencies; parameters 5 to 8 are taken in order to analyze system performance.				
	Raw Sewage Parameter	Type of Sample	Minimum Frequency	Total # of Samples
1	CBOD ⁵	grab	monthly	12
2	Suspended Solids	grab	monthly	12
3	Total Phosphorus	grab	monthly	12
4	Total Kjeldahl Nitrogen	grab	monthly	12
5	Ammonia (N)	grab	monthly	12
6	Nitrite (N)	grab	monthly	12
7	Nitrate (N)	grab	monthly	12
Certificate of Analysis 4.(c) Samples of effluent from the waste stabilization pond shall be collected at locations acceptable to the District Manager and analyzed for at least the following parameters(1-10) at the indicated minimum frequencies.				
	Waste Stabilization Pond Effluent Parameter	Type of Sample	Minimum Frequency	Total # of Samples
1	CBOD5	grab	weekly	52
2	Suspended Solids	grab	weekly	52
3	Total Phosphorus	grab	weekly	52
4	Total Kjeldahl Nitrogen	grab	weekly	52
5	Ammonia (N)	grab	weekly	52
6	Nitrite (N)	grab	weekly	52
7	Nitrate (N)	grab	weekly	52
8	pH	grab	weekly	52
9	Temperature	grab	weekly	52
10	E. Coli	grab	monthly	12
Certificate of Analysis 4.(d) Samples of effluent from the constructed wetland shall be collected at locations acceptable to the District Manager and analyzed for at least the following parameters (1-9) at the indicated minimum frequencies. E. Coli is sampled to comply with C. of A. objective 5.(b).				
	Constructed Wetland Effluent Parameter	Type of Sample	Minimum Frequency	Total # of Samples
1	CBOD5	grab	weekly	52
2	Suspended Solids	grab	weekly	52
3	Total Phosphorus	grab	weekly	52
4	Total Kjeldahl Nitrogen	grab	weekly	52
5	Ammonia (N)	grab	weekly	52
6	Nitrite (N)	grab	weekly	52
7	Nitrate (N)	grab	weekly	52
8	pH	grab	weekly	52
9	Temperature	grab	weekly	52
10	E. Coli	grab	monthly	12

Certificate of Approval (5.)(c) Stipulates that the Owner shall endeavor to operate the sewage treatment works such that the effluent will not contain any oil or other substance in amounts sufficient to create a visible film or sheen on the surface of the receiving waters and shall be essentially free of any floating material.

Occasional foaming was present where wastewater cascades over weirs or from outfalls; this appears to occur on a seasonal basis.

Certificate of Approval 6.(a) refers to proper maintenance of related equipment and appurtenances to operate sewage works, including funding for operator training.

In December of 2009 upgrades to the warning (monitoring) at the Harbour Street Pumping Station, to include the pumps individually and compressors, generator (when on), high water levels in the wetwell, high water in the drywell, and pump over heating .In 2011 an auto start was added to the generator to exercise it once a week. Regular Cleaning of the wetwells is now being done on a yearly basis to prevent damage to the pumps, also Alarms were added to the buildings for intrusion, the lagoon alarms have been added for various problems that could occur.

Computers are used to monitor the flows at both the liftstation and Lagoon, the lagoon computer is tied into the flow reader to provide up to date flows. At the lift station the operator inputs day to day information and flows. The Wetland now has hydro and a data cable (data for future use) all the way over to the far side so that flows can be monitored as per C of A.

An Operations and Maintenance Manual is in place at the Sewage Works. Continuing education for operators is promoted by the municipality for wastewater treatment and collection as well as health, safety, and technical related courses.

Certificate of Approval 7.(c) Flows through the Brighton Wastewater Treatment lagoons and wetlands are continuous.

Certificate of Approval 7.(d)(i) Summary of all monitoring data including an overview of the sewage treatment program.

Certificate of Approval 7.(d)(ii) Interpretation of all monitoring and analytical data and comparison to the final effluent quality and quantity.

Table IX Brighton WPCP Performance Summary details results and efficiency of the sewage treatment performance demonstrating pollutant removal rates from raw sewage concentrations through to final effluent for CBOD₅, Suspended Solids, Total Phosphorus, TKN and Ammonia.

Table IX also demonstrates the success of Brighton's WPCP natural treatment process, which includes:

- 88.4% CBOD₅ removal
- 93.9% removal of Suspended Solids
- 93.7% removal of Phosphorus
- 56.2% removal of Nitrogen
- 48.5% removal of Ammonia

Certificate of Approval 7.(d)(iii) Summary of any final effluent quality assurance or control measures undertaken during the reporting period.

Table IX

Month	Flows			CBOD5				Suspended Solids			
	Total Flow m ³	Average Day m ³ /D	Maximum Day m ³ /D	Raw Sewage (mg/L)	Lagoon #1 (mg/L)	Lagoon #2 (mg/L)	Wetland Effluent (mg/L)	Raw Sewage (mg/L)	Lagoon #1 (mg/L)	Lagoon #2 (mg/L)	Wetland Effluent (mg/L)
Jan.	87,273	2,815	3,935	66.00	18.00	11.00	6.50	110.00	86.00	23.50	9.50
Feb.	85,999	3,071	8,073	72.00	38.00	10.75	8.00	126.00	80.00	32.00	17.50
Mar.	198,704	6,410	11,899	30.00	6.00	12.40	18.60	60.00	66.00	25.60	12.00
Apr.	155,182	5,173	7,684	72.00	19.00	10.00	4.75	118.00	70.00	20.00	12.00
May	148,894	4,803	5,740	36.00	23.00	9.00	2.80	84.00	60.00	15.60	4.20
June	109,064	3,635	4,552	72.00	36.00	2.50	2.25	125.00	210.00	5.00	4.25
July	84,233	2,717	3,517	138.00	13.00	8.75	3.75	355.00	136.00	16.75	9.25
Aug.	106,377	3,432	6,571	114.00	9.00	2.00	4.00	195.00	114.00	8.40	3.80
Sept.	73,625	2,454	2,106	96.00	18.00	2.75	2.00	182.00	88.00	2.75	3.00
Oct.	83,578	2,696	4,269	120.00	48.00	2.00	2.50	148.00	84.00	5.50	6.50
Nov.	82,646	2,755	5,824	84.00	36.00	2.20	3.25	86.00	90.00	4.60	4.75
Dec.	135,976	4,386	6,551	60.00	9.00	3.75	2.75	150.00	46.00	9.50	5.00
Total	1,351,551										
Average	112,629	3,696		80.00	22.75	6.43	5.10	144.92	94.17	14.10	7.65
C. of A.		4,600				30.0	15.0			40.0	15.0
% Efficient					71.6%	92.0%	93.6%		35.0%	90.3%	94.7%
			*Lag2 =lagoon 2			*Vel=Wetland					

Month	Total Phosphorous				lag2	TKN				lag2	Ammonia				Temp
	Raw Sewage (mg/L)	Lagoon #1 (mg/L)	Lagoon #2 (mg/L)	Wetland Effluent (mg/L)		Raw Sewage (mg/L)	Lagoon #1 (mg/L)	Lagoon #2 (mg/L)	Wetland Effluent (mg/L)		Raw Sewage (mg/L)	Lagoon #1 (mg/L)	Lagoon #2 (mg/L)	Wetland Effluent (mg/L)	
Jan.	320	240	1.04	0.68	1.0	30.00	20.00	18.73	17.28	17.0	21.90	16.20	16.70	15.55	3.88
Feb.	360	250	1.20	0.68	1.0	34.50	23.50	20.95	17.50	17.0	32.50	23.60	20.20	20.23	2.00
Mar.	270	216	0.54	0.33	1.0	20.90	20.30	11.44	10.94	17.0	19.70	16.20	8.66	9.80	4.52
Apr.	360	1.91	0.45	0.33	1.0	37.00	16.10	11.78	12.00	17.0	22.90	6.00	7.68	5.48	9.63
May	290	1.78	0.45	0.18	1.0	21.00	11.70	11.60	6.68	14.0	22.20	11.00	10.02	6.80	16.60
June	450	3.50	0.28	0.33	1.0	39.00	25.00	16.05	13.90	14.0	29.00	15.80	15.25	13.23	22.93
July	7.00	3.20	0.56	0.25	1.0	43.00	18.50	18.55	18.55	14.0	34.00	15.80	17.67	9.33	0.00
Aug.	6.00	1.00	0.44	0.25	1.0	55.00	26.00	19.90	15.30	14.0	43.00	18.30	18.44	14.74	0.00
Sept.	5.70	0.03	0.38	0.23	1.0	48.00	26.00	22.03	17.65	14.0	42.50	22.10	21.28	17.08	0.00
Oct.	4.20	0.32	0.44	0.28	1.0	37.00	27.00	24.98	22.13	14.0	33.00	22.70	22.55	20.43	0.00
Nov.	3.08	2.44	0.24	0.17	1.0	27.90	21.10	21.22	19.63	17.0	22.70	16.90	19.18	17.90	0.00
Dec.	2.20	1.58	0.28	0.15	1.0	19.20	14.20	13.68	11.90	17.0	12.00	9.50	11.53	10.31	0.00
	4.06	1.90	0.52	0.32		34.38	20.78	17.57	15.29		27.95	16.18	15.76	13.40	
			1.00	0.80									14.0 (S) 17.0 (W)	10.0 (S) 15.0 (W)	
			53.1%	87.1%			39.5%	48.9%	55.5%			42.1%	43.6%	52.0%	
													22.55	20.43 max	
													7.68	5.48 min	

Certificate of Approval 7.(d)(iv) Summary of maintenance carried out on major structure, equipment, apparatus, mechanism forming part of the works.

- Upgrades have also been carried out at the lagoon with the installation of a new Alarm system.
- Yearly Wetwell cleaning is being done
- This year water levels were dropped in the wetland to allow for new growth to naturally occur, with good success.
- Yearly flushing and video inspection of the Municipalities Sanitary Sewer System is being done to better determine if repairs or replacement of infrastructure is needed.

Certificate of Approval 7.(d)(v) Summary of any environmental or operating problems encountered and mitigative measures taken.

- Although there are no combined sanitary and storm sewers in Brighton, the collection system is susceptible to higher flows with heavy precipitation events. This is a result of infiltration of storm water into the collection system and suspected illegal connections of sump pump discharges.
- Muskrat damage to the constructed wetlands has reduced plant growth in the vegetated zones. Seasonal trapping is being conducted to control muskrat population. This has become an annual situation due to the natural conditions for muskrats.

Certificate of Approval 7.(d)(vi) Summary of alterations, extensions or replacements in the process or operation of the works which are considered for implementation over the next reporting period.**Certificate of Approval 7.(d)(iv) Summary of calibration and maintenance procedures conducted on all monitoring equipment.**

Milltronics performed annual calibration of flow meters at the Brighton WPCP on August.

4.4 Reporting – Non-Compliance

- **Certificate of Approval 7.(b)** There were non-compliance issues in this reporting period.

4.5 **Future Action Plan**

In 2011, Ammonia problems re-occurred, the problem we believe is that the sludge build up has continued and compounded the problem and once again resulted in non-compliance. The spring of 2012 is when the lagoon will be dredged which should resolve this issue. Brighton Council has been informed by our Consultants (AECOM) and will be proactive with their recommendation:

5.0 **CONCLUSION**

The Brighton Water Pollution Control Plant has been successful in treating the wastewater utilizing the lagoons and wetlands through natural treatment processes. The final quality of the effluent may be influenced by a majority of environmental factors such as climate or wildlife. Enhanced performance is exhibited during warmer months when nutrients are absorbed from the growth of vegetation and bacteria are most active. Wastewater effluent from the wastewater pollution control plant (WPCP) is tested at Caduceon Environmental Labs, a certified lab, on a weekly basis as per Certificate of Approval. Effluent quality from the lagoon and wetland site to Presqu'ile Bay has met and/or exceeded the contaminant limits and objectives set under the terms and conditions of the Certificate of Approval. Brighton is dedicated to achieving continuous improvement of its wastewater treatment system and being environmentally responsible to the quality of its receiving waters.