



**Brighton Fire & Rescue**  
20 Elizabeth Street  
P.O. Box 126, Brighton, ON K0K 1H0  
Telephone: 613-475-1744 Fax: 613-475-1385  
Fire Chief – Rick Caddick CEMC – CMM III

April 15 2019

**Outdoor Events and Festival Requirements**  
**Outdoor Cooking / Heating Equipment**

Dear Vendor:

We want to thank you for your willingness to participate in our local events. To ensure your safety and the safety of all our event participants we want you to be aware of the following requirements. Representatives of Brighton Fire & Rescue will be around to inspect your area prior to opening of the event. Failure to comply with the regulations could result in your organizations cooking operations being shut down until compliance is achieved.

**General Requirements for Outdoor Cooking/Heating:**

- Tents and canopies used to shelter cooking / heating equipment shall be flame retardant
- A minimum clearance of 3m (10') shall be maintained between all cooking /heating equipment and combustibles.
- All cooking equipment shall be kept a safe distance from overhanging trees and other foliage
- A portable fire extinguisher with a minimum 2A/10B/C rating shall be provided for all cooking operations. The minimum size of 5 Lbs.
- Every refreshment vehicle shall be equipped with a portable fire extinguisher with a minimum 2A/10B/C rating. Where an approved fixed extinguishing system is required, a portable "K" class fire extinguisher shall be provided.
- Where a fixed extinguishing /hood system is present, a valid (within six months from the date of the event) certificate of service/inspection issued by a qualified person shall be provided.



**Brighton Fire & Rescue**  
20 Elizabeth Street  
P.O. Box 126, Brighton, ON K0K 1H0  
Telephone: 613-475-1744 Fax: 613-475-1385  
Fire Chief – Rick Caddick CEMC – CMM III

April 15, 2019

**Outdoor Events and Festival requirements**

- A valid Inspection Certificate (Director's Order #FS-056-06) issued by the Technical Standards and Safety Authority (TSSA) shall be provided. TSSA is the authority having jurisdiction over propane/natural gas equipment. The local TSSA inspector shall be notified prior to the operation of every refreshment vehicle by calling 1.705.761.1802.
- The Kawartha Pine Ridge Health Unit must be consulted, and any rules and regulations followed for compliance.

The Municipality of Brighton and Brighton Fire & Rescue is committed to ensuring that all our public events are enjoyable and safe for all who wish to attend. Your complete cooperation with these rules and regulations will ensure that we are all successful and provide an enjoyable event for our residents and guests

Respectfully

**Rick Caddick** CMM III  
Fire Chief / CEMC  
Brighton Fire and Rescue